



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

1	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.04.2026	BY (Time)	1415 PST
--------------	------------	--------------	----------

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	<p><u>D/U Twin Electronic Suction</u></p> <p>SUPPLY OF TWIN SUCTION DISPENSING UNITS:</p> <p>TYPE:</p> <ul style="list-style-type: none"> - Suction Type. - Self-Contained for Flammable Products. - To be used for Gasoline (all Research Octane Number # RON from 87 to 97), Diesel and ethanol blends products. - Operating Temperature: -10°C to +55°C (Must have good suction ability in extreme hot weather specially for Gasoline products). - Temperature range can be modified to utilize the units in extreme weather. - Contain: Anti-Cheat / Theft Features. - Valance / Canopy. - Dispensing Unit to be ATEX / UL-87 / KHK Certified. - Electrically Operated: Single Phase 220V AC (±10%), 50 Hz. <p>TWIN TYPE UNITS CONTAINS:</p> <ul style="list-style-type: none"> - Two Nozzles, Two Nozzle Boots, Two High Hoses. - Two Displays (one for each Nozzle on both sides of panel). - Two Keypads. - Single Product Dispensing units. - Single Pumping Unit & Motor. 	<u>Keamari Terminal</u>	<u>EA</u>	50		
2	<p><u>D/U Twin Electronic Remote</u></p> <p>SUPPLY OF TWIN REMOTE DISPENSING UNITS:</p> <p>TYPE:</p> <ul style="list-style-type: none"> - Remote Type. - Self-Contained for Flammable Products. - To be used for Gasoline (all Research Octane Number # RON from 87 to 97), Diesel and ethanol blends products. - Operating Temperature: -10°C to +55°C (Must have good suction ability in extreme hot weather specially for Gasoline products). 	<u>Keamari Terminal</u>	<u>EA</u>	25		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

2	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.04.2026	BY (Time)	1415 PST
--------------	------------	--------------	----------

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
3	<ul style="list-style-type: none"> - Temperature range can be modified to utilize the units in extreme weather. - Contain: Anti-Cheat / Theft Features. - Valance / Canopy. - Dispensing Unit to be ATEX / UL-87 / KHK Certified. - Electrically Operated: Single Phase 220V AC ($\pm 10\%$), 50 Hz. <p>TWIN TYPE UNITS CONTAINS:</p> <ul style="list-style-type: none"> - Two Nozzles, Two Nozzle Boots, Two High Hoses. - Two Displays (one for each Nozzle on both sides of panel). - Two Keypads. - Single Product Dispensing units. - Single Pumping Unit & Motor. <p><u>D/U Quadro Electronic Suction</u></p> <p>SUPPLY OF QUARDO SUCTION DISPENSING UNITS:</p> <p>TYPE:</p> <ul style="list-style-type: none"> - Suction Type. - Self-Contained for Flammable Products. - To be used for Gasoline (all Research Octane Number # RON from 87 to 97), Diesel and ethanol blends products. - Operating Temperature: -10°C to +55°C (Must have good suction ability in extreme hot weather specially for Gasoline products). - Temperature range can be modified to utilize the units in extreme weather. - Contain: Anti-Cheat / Theft Features. - Valance / Canopy. - Dispensing Unit to be ATEX / UL-87 / KHK Certified. - Electrically Operated: Single Phase 220V AC ($\pm 10\%$), 50 Hz. <p>QUADRO TYPE UNITS CONTAINS:</p> <ul style="list-style-type: none"> - Four Nozzles, Four Nozzle Boots, Four High Hoses. - Four Displays (one for each Nozzle on both sides of panel). - Four Keypads. 	<u>Keamari Terminal</u>	EA	40		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

3	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.04.2026	BY (Time)	1415 PST
--------------	------------	--------------	----------

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
4	<ul style="list-style-type: none"> - Two Product Dispensing units. - Two Pumping Unit & Motor. <p><u>D/U Quadro Electronic Suction</u></p> <p>SUPPLY OF QUARDO SUCTION DISPENSING UNITS:</p> <p>TYPE:</p> <ul style="list-style-type: none"> - Suction Type. - Self-Contained for Flammable Products. - To be used for Gasoline (all Research Octane Number # RON from 87 to 97), Diesel and ethanol blends products. - Operating Temperature: -10°C to +55°C (Must have good suction ability in extreme hot weather specially for Gasoline products). - Temperature range can be modified to utilize the units in extreme weather. - Contain: Anti-Cheat / Theft Features. - Valance / Canopy. - Dispensing Unit to be ATEX / UL-87 / KHK Certified. - Electrically Operated: Single Phase 220V AC (±10%), 50 Hz. <p>QUADRO TYPE UNITS CONTAINS:</p> <ul style="list-style-type: none"> - Four Nozzles, Four Nozzle Boots, Four High Hoses. - Four Displays (one for each Nozzle on both sides of panel). - Four Keypads. - Two Product Dispensing units. - Two Pumping Unit & Motor. 	<u>Keamari Terminal</u>	<u>EA</u>	84		
5	<p><u>D/U Three Product Suction</u></p> <p>SUPPLY OF 3 PRODUCT SUCTION DISPENSING UNITS:</p> <p>TYPE:</p> <ul style="list-style-type: none"> - Suction Type. - Self-Contained for Flammable Products. - To be used for Gasoline (all Research Octane Number # RON from 87 to 97), Diesel and ethanol blends products. 	<u>Keamari Terminal</u>	<u>EA</u>	20		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
 Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

4	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
 SAP No.6100016115

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED			
	ON (Date)	20.04.2026	BY (Time)	1415 PST

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY** Fix %
 Rs. _____ PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
6	<ul style="list-style-type: none"> - Operating Temperature: -10°C to +55°C (Must have good suction ability in extreme hot weather specially for Gasoline products). - Temperature range can be modified to utilize the units in extreme weather. - Contain: Anti-Cheat / Theft Features. - Valance / Canopy. - Dispensing Unit to be ATEX / UL-87 / KHK Certified. - Electrically Operated: Single Phase 220V AC (±10%), 50 Hz. <p>THREE PRODUCT UNITS CONTAINS:</p> <ul style="list-style-type: none"> - Six Nozzles, Six Nozzle Boots, Six High Hoses. - Four Displays per unit (2 displays per side). - Four Keypads. - Three Products Dispensing units. - Three Pumping Units & Motors (one for each product). - Capable for simultaneous fueling by 4 hoses at same time - Out of 2 displays per side, one display is allocated for two product and one product is allocated for single product. <p><u>Installation of Dispensing Units</u></p>	PSO House				
6.01	<p><u>Installation, Testng and Commisoning De</u></p> <ul style="list-style-type: none"> - Installation of Twin Suction Dispensing Units (Twin Nozzle D/U) anywhere in Pakistan. 		EA	50		
6.02	<p><u>Installation, Testng and Commisoning De</u></p> <ul style="list-style-type: none"> - Installation of Twin Remote Dispensing Units (Twin Nozzle D/U) anywhere in Pakistan. 		EA	25		
6.03	<p><u>Installation, Testng and Commisoning De</u></p> <ul style="list-style-type: none"> - Installation of Quadro Suction Dispensing Units (Quadro Nozzle D/U) anywhere in Pakistan. 		EA	124		
6.04	<p><u>Installation, Testng and Commisoning De</u></p> <ul style="list-style-type: none"> - Installation of 3 Product Suction Dispensing Units (6 Nozzles D/U) anywhere in Pakistan. 		EA	20		
7	<p><u>Maintenance of Dispensing Units</u></p>	PSO House				
7.01	<p><u>Maintenance of Dus Miscellaneous</u></p>		EA	600		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
 Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

5	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
 SAP No.6100016115

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED		
	ON (Date)	20.04.2026	BY (Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY** Fix %
 Rs. _____ PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
7.02	- Maintenance of out of warranty Dispensing Units (Twin Suction D/U) in all over Pakistan as per Tripartite Agreement. Maintenance of Dus Miscellaneous		EA	300		
7.03	- Maintenance of out of warranty Dispensing Units (Twin Remote D/U) in all over Pakistan as per Tripartite Agreement. Maintenance of Dus Miscellaneous		EA	1,488		
7.04	- Maintenance of out of warranty Dispensing Units (Quadro Suction D/U) in all over Pakistan as per Tripartite Agreement. Maintenance of Dus Miscellaneous		EA	240		
	===== ===== COMPLETE SEPCIFICATIONS OF ALL TYPES DUs: 01) HEIGHT & WIDTH: - Height: 7 ft to 8 ft. (for all Dispensing Units). - Width: 4 ft to 4.5 ft. (for 3 Product Dispensing Unit). 02) PUMPING UNIT (ONLY FOR SUCTION TYPE ONLY): - Positive Displacement. - Internal Gear Type Rotary. - Self-Priming. - Internal Air Separator. - Adjustable by Pass Valve. - Inlet Filter / Strainer. - Rated Head / Suction Lift (Min.): from Pump Base to the Bottom of the Tank should be more than 3 m. - Suction Length (Min.): 100 ft - 150 ft. 03) MOTOR (ONLY FOR SUCTION TYPE ONLY): - 1 HP Minimum, Continuous Duty. - Single Phase, 220V AC (±10%), 50 Hz. - Explosion Proof Class 1, Group D.					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

6	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED			
	ON (Date)	20.04.2026	BY (Time)	1415 PST

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY** Fix %
Rs. _____ PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<ul style="list-style-type: none"> - Flame-Proof Certification. - Totally Enclosed. - Thermally Protected. - Over-Voltage Protected. - Motor Insulation Selection: Motor Winding must comply with Class F Insulation range as per NEMA Insulation Classes. - Motor Overheat & Surge Protection: The protection provided in Dispensing Units for motor as well as electronics against surges/spikes shall be specified. Vendor internal QA procedure must consist of, among others, carrying out the following tests: <ul style="list-style-type: none"> -- Electrical Fast Transient Test (As per IEC-61000-6-1 standard IEC-61000- 4-4). -- Surge Test (As per IEC-61000-6-1 Standard IEC-61000-4-5). -- Electrostatic discharge test (As per IEC-61000-6-1 Standard IEC-61000-4-2). -- Voltage interruptions and dips (As per IEC-61000-6-1 Standard IEC-61000- 4-11). 04) DELIVERY RATE: <ul style="list-style-type: none"> - 40-50 Liters/Minute for single nozzle. 05) CONNECTION: <ul style="list-style-type: none"> - Intake Connection: 1-1/2 inch Dia or as per OEM recommendation. # Product Pipeline: 50mm dia. UPP. 06) METERING UNIT: <ul style="list-style-type: none"> - One for each nozzle - Accuracy ± 0.25% min. 07) FLOW CONTROL VALVE: <ul style="list-style-type: none"> - Multi-stage, Solenoid actuated valves 08) HOSE PIPE: <ul style="list-style-type: none"> - 4 Meter long. - 20mm Dia. 					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

7	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED		
	ON (Date)	20.04.2026	BY (Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY** Fix %
Rs. _____ PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<ul style="list-style-type: none"> - Flexible wire reinforced. - Petrol/Diesel/Ethanol blended Petrol Resistant. - Hose hook (hanger) at front door panel. - Color: Black. <p>09) BREAK AWAY COUPLING:</p> <ul style="list-style-type: none"> - One for each high Hose. - Re-usable / Re-connectable type with short hose for use in Flammable liquids. - Standard 3/4" NPT fitting. - Instant seals at both ends of break. - Ability to automatically stop the flow of fuel and limit fuel spillage when break. - Ability to absorb the effects of normal line shock. - Ability to easily reconnect. <p>10) SWIVEL MECHANISM / SYSTEM:</p> <ul style="list-style-type: none"> - Swivel mechanism/system to be provided with hose pipe. <p>11) NOZZLE:</p> <ul style="list-style-type: none"> - Automatic shut-off nozzle. - 3/4" dia. - Splash guard. <p>12) NOZZLE BOOT:</p> <ul style="list-style-type: none"> - To be provided at front. <p>13) MEMORY BACKUP:</p> <ul style="list-style-type: none"> - Sales display visible up to 15 minutes. - Data storage up to 5 years. <p>14) TOTALIZER:</p> <ul style="list-style-type: none"> - 7-digit non-resettable electro-mechanical totalizer. - 10-digit money & 10-digit volume electronic totalizer. 					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

8	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.04.2026	BY (Time)	1415 PST
--------------	------------	--------------	----------

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<p>15) KEYPAD SYSTEM:</p> <ul style="list-style-type: none"> - One for each Nozzle on both sides of panel. - Minimum 16 Buttons Keypad. - Numeric buttons. - Pre-set buttons. - Confirmation of pre-set money or volume. <p>16) DISPLAY MODULE:</p> <ul style="list-style-type: none"> - Backlit LCD/LED Digital display. - Easily visible in day & night operation. - min 7-digit money counter (Label Rupees). - min 6-digit volume counter (Label Liters). - min 5-digit price display (Label Rupees / Liters). - Quality & Type: Industrial grade type to withstand temperature range of -10°C to +80°C. <p>17) MOTOR DRIVE:</p> <ul style="list-style-type: none"> - V Belt. <p>18) OVER VOLTAGE PROTECTION RELAY:</p> <ul style="list-style-type: none"> - To be provided to protect electric components in case of over voltage. <p>19) EMERGENCY SWITCH:</p> <ul style="list-style-type: none"> - At front panel for immediate shut off. <p>20) BASE:</p> <ul style="list-style-type: none"> - Cast Steel or Anodized extruded Aluminum, Powder Coated. <p>21) FRAME:</p> <ul style="list-style-type: none"> - Steel structure / Anodized extruded Aluminum. <p>22) PANELS:</p> <ul style="list-style-type: none"> - MS Plate, Bake Painted or Painted Aluminum. <p>23) EXTERIOR PAINT COLOUR:</p>					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

9	OF	*
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED		
	ON (Date)	20.04.2026	BY (Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<p>- Preferably White.</p> <p>- Panels and enclosures should be powder coated for prolonged life and better finish.</p> <p>24) LOCKS: - With keys.</p> <p>25) INTERLOCKING: - Electronic interlocking in nozzle with processor & motor.</p> <p>26) DATA COMMUNICATION: - The OEM shall provide all the details of DU communication protocol and Dispensing Unit (DU) shall be capable of providing following information and performing operations upon request from IOT device: -- Sale Transaction (Sales Data). -- Totalizer (Sales Data). -- Product wise rate change. -- DU Lock/Unlock. -- Auto/Manual mode switch. -- Remote Password Management. -- Any other information at DU as deemed necessary by PSO OEM shall share complete details of dispensing unit communication protocol at RS485/ Ethernet (UDP) port for each level (Level 1, level 2, level 3 and any other level) upto PSO#s satisfaction for the integration purpose. OEM shall also provide every detail/information about any other proprietary/open protocol(s) that is essential to integrate DU with IOT device and perform desired functionalities as explained in the Dispensing Unit Integration Communication Protocol part attached as Annexure A.</p> <p>27) PULSER: - Solid State Pulsar. - Meter mounted. - Fail safe design. - Pulsar Safety Feature: In the event of 1st sensor failure the ERA will</p>					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

10	OF	13
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.04.2026	BY (Time)	1415 PST
--------------	------------	--------------	----------

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<p>annunciate same but the pump will continue to operate. In the event of second sensor failure the ERA will annunciate and the pump will stop till repair is undertaken.</p> <p>28) COMPUTER: - Micro Processor based control system.</p> <p>29) PROGRAMMING: - Price setting and other functionalities. - Input through infra-red remote or keypad menu.</p> <p>30) PRINTER: - Capable and compatible for installing thermal printer. - The DU should have port and interface for future thermal printer installation.</p> <p>31) GRAPHICS: - Green & White wave color pattern with powder coating on door panel with PSO Logo. - Green & White wave color pattern with powder coating on canopy / valance. Design to be provided by PSO.</p> <p>32) PACKING: - Shock proof Wooden frame with hard board ply wood packing for safe handling & lifting.</p> <p>33) SPARE PARTS: - It will be responsibility of the OEM to ensure availability of spare parts at its local representative work shop during warranty period and maintenance contract.</p> <p>34) WARRANTY: - Warranty period of 24 months from date of equipment supply at PSO store.</p>					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

11	OF	13
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED			
	ON (Date)	20.04.2026	BY (Time)	1415 PST

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY** Fix %
Rs. _____ PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<p>35) INSPECTION:</p> <ul style="list-style-type: none"> - Acceptance of equipment shall be subject to prior inspection by any PSO nominated 3rd party (to be arranged by PSO) or PSO employees in the country of origin. The Supplier / Manufacturer will arrange equipment inspection at their warehouse / Factory premises which will include the performance test of DU. <p>36) TRAINING OF PSO STAFF:</p> <ul style="list-style-type: none"> - Supplier of equipment will arrange to conduct training course for training of 30-40 engineers / technician in 3 different cities to educate in the repairing & maintenance of electronic digital pump comprising of atleast one-week long course (2 days in each city) after procurement of Dispensing Units at his own cost. <p>37) OTHERS:</p> <ul style="list-style-type: none"> - FXA Plate: "Fixed Asset Number (FXA)" to be printed / embossed on each machine at a clearly visible place in the following SAMPLE format: - PSO FXA # 38005765 The printing / embossing should be of permanent type and not peel off or fade out with time. The series of Fixed Asset Numbers for all machines will be provided at the time of issuance of Purchase Order. The same number should appear on the packing of the machine for ease of identification. <p>38) HSE REQUIREMENTS:</p> <ul style="list-style-type: none"> - Over Voltage Protection Relay: to be provided to protect electric components in case of over voltage / surge. - On/Off Switch to be provided inside panel of DUs - Emergency Switch to be provided on front panel of DUs in case of fire incident shut off immediately. - Self-Diagnosis to stop operation automatically if failed - Electronic interlocking - Nozzle cover should be provided so that evaporation of fumes could be minimized during fueling vehicle tank. <p>39) SCOPE OF WORK FOR INSTALLATION/TESTING/COMMISSIONING OF DISPENSING</p>					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

12	OF	13
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.04.2026	BY (Time)	1415 PST
--------------	------------	--------------	----------

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY** Fix %
Rs. _____ PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<p>UNITS:</p> <ul style="list-style-type: none"> - Contractor has overall responsibility for installation of Dispensing Unit. The contractor will arrange tools and labor for the installation of Dispensing unit at site, anywhere in Pakistan, no mobilization charges will be given separately. The scope of work includes but not limited to following: 1- Connection of DU pumping unit with UPP piping including all accessories required for connection. The piping work from underground fuel storage tanks to island is not part of contractor scope of work. 2- Contractor to make the electrical connection of dispensing unit, the scope includes providing cable joints, cable terminations and other accessories required for connection of dispensing unit. The cabling work from distribution board to the dispensing unit is not part of scope of contractor. 3- Contractor to connect the dispensing unit with the existing earthing system of the outlet and take a reading of earthing of dispensing unit, in case the earthing is less than 5 ohms than DU will be commissioned, but in case reading is more than 5 ohms the contractor will inform concerned divisional engineer regarding the same for rectification work. DU will only be commissioned when the reading is less than 5 ohms. 4- Contractor to perform all activities related to the commissioning of the dispensing unit and perform all checks highlighted by PSO, local government agencies and mentioned by OEM for installation of dispensing unit. 5- Contractor will provide certificate of installation and commissioning of dispensing unit signed by divisional engineer, dealer of site and contractor to PSO head office. <p>40) SCOPE OF WORK FOR MAINTENANCE OF DISPENSING UNITS:</p> <ul style="list-style-type: none"> - The scope of work is mentioned in Tripartite agreement of DUs maintenance. <p>41) DELIVERY SCHEDULE:</p> <ul style="list-style-type: none"> - Bidder to comply with timeline mentioned in Special Terms & Condition. 					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

13	OF	13
RFQ No	RC-19555IA	
DATE	15.03.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100016115

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.04.2026	BY (Time)	1415 PST
--------------	------------	--------------	----------

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply, Installation and Maintenance of Dispensing Units for PSO Retail Outlets.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	42) SPECIAL TERMS AND CONDITIONS and draft TRIPARTITE CONTRACT attached with the tender is also part of this RFQ.					
	43) AMOUNT OF BID SECURITY: - For Supply = PKR. 10,000,000/- (or equivalent amount in Foreign Currency). - For Installation and Maintenance = PKR. 250,000/-.					