



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

1	OF	3
RFQ No	GF-19856YP	
DATE	28.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017606

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

12.08.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Installation of Fire detection system at PSO LPG Plant Korangi.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	<u>Installation of Fire detection</u>	<u>Korangi</u>				
1.01	<u>Installation of 1" uPVC Conduit/Flexible</u>	<u>(LPG)</u>	<u>FT</u>	1,246.720		
	Installation of 1" uPVC Conduit/Flexible with Hardware Fitting and Laying of 2 Core 1.5sq.mm Fire Resistant Cable ,,					
2	<u>FIRE ALARM CONTROL PANEL</u>	<u>Korangi</u>	<u>EA</u>	1		
	4 Loop Addressable Fire Detection & Alarm Control Panel With 1 Loop Card, LCD & Power Supply Unit Approvals: UL Listed/FM Approved<(>,<)>	<u>(LPG)</u>				
3	<u>BATTERY 12V</u>	<u>Korangi</u>	<u>EA</u>	2		
	12V 18Ah Backup Batteries for Addressable Fire Alarm Panel ,,	<u>(LPG)</u>				
4	<u>SMOKE DETECTOR</u>	<u>Korangi</u>	<u>EA</u>	8		
	Addressable Optical Smoke Detector with Standard Base Approvals: UL Listed/FM Approved.	<u>(LPG)</u>				
5	<u>HEAT DETECTOR</u>	<u>Korangi</u>	<u>EA</u>	3		
	Addressable Optical Smoke and Heat (Multi) Detector with Standard Base Approvals: UL Listed/FM Approved.	<u>(LPG)</u>				
6	<u>HEAT DETECTOR</u>	<u>Korangi</u>	<u>EA</u>	2		
	Addressable Temperature/Heat Detector with Standard Base Approvals: UL Listed/FM Approved.	<u>(LPG)</u>				



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

2	OF	3
RFQ No	GF-19856YP	
DATE	28.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017606

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

12.08.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Installation of Fire detection system at PSO LPG Plant Korangi.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
7	<u>Addressable NBG-12L Pull Station</u> Addressable Manual Pull Station - Double Action, 1-stage Approvals: UL Listed/FM Approved.	<u>Korangi</u> <u>(LPG)</u>	<u>EA</u>	2		
8	<u>Sounder with Flasher</u> Conventional Sounder with Flasher, 15-75cd, Red, FIRE Marking Approvals: UL Listed/FM Approved.,,	<u>Korangi</u> <u>(LPG)</u>	<u>EA</u>	2		
9	<u>Loop Control Module</u> Addressable Loop Isolator Module Approvals: UL Listed/FM Approved.,,	<u>Korangi</u> <u>(LPG)</u>	<u>EA</u>	1		
10	<u>UPS</u> Online Uninterruptible Power Supply (UPS) 1 KVA with Battery ,,	<u>Korangi</u> <u>(LPG)</u>	<u>EA</u>	1		
11	<u>1.5 sq mm 2 core fire resistant cable</u> Core 1.5sq.mm Fire Resistant Cable, PH-120 (LPCB Approved / UL Listed),,	<u>Korangi</u> <u>(LPG)</u>	<u>M</u>	380		
12	<u>UPVC PIPE 1"</u> uPVC Conduit/Flexible Pipe 25mm Dia with Hardware Fittings	<u>Korangi</u> <u>(LPG)</u>	<u>M</u>	320		
13	<u>Installation, Testing, Commissioning</u>	<u>Korangi</u> <u>(LPG)</u>				
13.01	<u>Installation, testing & Commissioning</u> Installation, Testing, Commissioning and Software Programming.,		<u>AU</u>	1		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

3	OF	3
RFQ No	GF-19856YP	
DATE	28.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017606

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

12.08.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Installation of Fire detection system at PSO LPG Plant Korangi.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	===== Notes: - - Contractor will provide Sales & Service Tax Invoice along with the bill. - Payment will be allowed after complete satisfaction of respective Plant Incharge/Plant Engineer on the basis of actual quantity. - The contractor will provide at least 12 months warranty. - Excavation required for the job, if any would be responsibility of the contractor. - The vendor is responsible for entire installation and commissioning of the system on turnkey basis that includes Engineering of the system (drawings, programming etc.) - Supply of complete material as stated below Complete installation of the material Commissioning of the complete detection system. - All government taxes are inclusive in above mentioned rates. - The charges include boarding and lodging of vendors staff All labor <(>,<)> tool, material, etc. to be provided by the contractor. - Contractor will fulfill all HSE requirements of the company. - Payment to the contractor is to be made as per actual measurement of work done. - Quality of work is the prime concern of PSO. The contractor will be required to produce / deliver best quality works.					