



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

1	OF	5
RFQ No	RC-19849IA	
DATE	29.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017593

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

13.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply of Fire Extinguishers for PSO Retail Outlets at Central Store KTB.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	<u>Fire Extinguisher 6 Kg DCP</u> DCP Fire Extinguisher 06 Kg (Wall Mounted). 1. Purpose: - The portable DCP Fire Extinguisher will be used to extinguish small fires in work places. Dry Chemical Extinguishers are intended primarily for use on Class A, B and C Fires. 2. Composition (Parts of Equipment): - Cylinder. - Discharge Hose with Nozzle. - Discharge Nozzle. - Pressure Gauge and Valve. 3. General Description: - Make & Model: Vendor to specify. - Country of origin: Vendor to specify. - Stored Pressure type. - Wall Mounted. - Propelling Agent: Nitrogen (Nitrogen gas shall be standard industrial grade with a dew point of 60°F (52.2°C) or lower.) - Imported Powder with proper Manufacturer certificate. - Colour: Post Office Red. 4. Material: - Material Cylinder: heavy duty steel Cylinder (Preferably SS) impact resistant, sand blasted & electro static powder coated. - Discharge Hose: PVC/ Rubber (Noncombustible and Non-Corrosive Material). - Length: 1-2ft. 5. Size: - 06 Kg	<u>Keamari Terminal</u>	<u>EA</u>	1,350		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

2	OF	5
RFQ No	RC-19849IA	
DATE	29.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017593

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

13.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply of Fire Extinguishers for PSO Retail Outlets at Central Store KTB.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	6. Technical Data: - Working Pressure: 14-20 bar. - Testing Pressure: 25-30 bar. - Maximum Range: Greater than 4 m - Discharge Time: 10-20 sec. - Discharge hose length: 1-2 ft. - Storage Temperature: -20°C to +60°C. 7.Approvals/ Certifications/ Compliance: - Manufacturing Standards: BSEN 3:2021 or equivalent. - Compliance NFPA Regulations. 8. Warranty: - One year. 9. HSE Requirements/Features: - Imported Gauge & Valve: with pressure release mechanism. - Hydrotest certificate valid within 5 years. 10. Accessories: - Wall Bracket. - Hose Holder. - Safety pin with chain. 11. General Requirements: - Serial Number should be punched on each cylinder along with water proof inspection tag. - Weather and chemical resistant instruction for use should be printed on Extinguishers. - Each Extinguisher should be covered in Nylon bag and packed in strong carton boxes.					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

3	OF	5
RFQ No	RC-19849IA	
DATE	29.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017593

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

13.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply of Fire Extinguishers for PSO Retail Outlets at Central Store KTB.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
2	<u>Fire Extinguisher DCP50Kg Trolley Mounted</u> Fire Extinguisher DCP50Kg Trolley Mounted 1. Purpose: - Trolley Mounted fire extinguisher will be used to extinguish fires in large work places. Dry Chemical type is intended primarily for use on Class A, B and C Fires. 2. Composition (Parts of Equipment): - Cylinder. - Discharge Hose. - Discharge Nozzle. - Pressure Gauge and Valve. 3. General Description: - Make & Model: Vendor to specify. - Country of origin: Vendor to specify. - Colour: Post Office Red. 4. Material - Cylinder must be of heavy duty Steel (preferably SS), corrosion and impact Resistant, sand blasted & electro static powder coated. - Discharge Hose: PVC (Flexible)/ Rubber (Non Combustible and non corrosive material). 5. Size: - 50 Kg. 6. Technical Data: - Extinguishing Agent: Dry Chemical Powder (ABC). - Propelling Agent: Nitrogen. - Working pressure: 12-15 bar. - Testing pressure: 25 bar.	<u>Keamari Terminal</u>	<u>EA</u>	265		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

4	OF	5
RFQ No	RC-19849IA	
DATE	29.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017593

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

13.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply of Fire Extinguishers for PSO Retail Outlets at Central Store KTB.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	- Maximum range: = 6 - 8 m. - Discharge time: 40 - 50 Sec. - Discharge Hose length: 5 m. - Storage temperature: -20°C to + 60°C. - Wheel: Rubberized mounted on metal/plastic rim (fire resistant) with ball bearing. 7. Approvals/ Certifications/ Compliance. - BSEN 1866: 2021 or Equivalent. - NFPA Complied. - Valid Hydrotesting Certificate (5 years validity period). 8. Warranty: - 1 Year after delivery at stores. 9. HSE Requirements/Features: - Imported Gauge and Valve: with pressure release mechanism. - Pressure: Sustainable pressure all the time. 10. Accessories: - Water Proof Inspection Tag. - Hose Holder. - Safety pin with chain. 11. General Requirements: - Serial number should be punched on each cylinder along with water proof inspection tag. - Weather and chemical resistant Instruction in English for use should be printed on Extinguishers. - Each Extinguisher should have a wrapping covered by air bubble poly ethane roll for protection during handling and storage. - Extinguisher type, capacity and user guidelines must be clearly pasted on cylinder.					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

5	OF	5
RFQ No	RC-19849IA	
DATE	29.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017593

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

13.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Supply of Fire Extinguishers for PSO Retail Outlets at Central Store KTB.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	===== NOTE: - All material to be delivered at PSO Warehouse at Kemari Terminal-B Karachi. - Delivery required within 90 days after issuance of Purchase Order. - The cylinder shall not be more than six months old from the date of Purchase Order issuance. - In accordance with the agreed delivery schedule, the Supplier shall deliver the materials in specified lots within the stipulated timelines as outlined in the Purchase Order/Contract. In the event of failure to deliver any lot, either in full or in part, within the specified time, a penalty shall be imposed on the undelivered quantity as follows: 1. Penalty Rate: A penalty at the rate of 0.1% of the total value of the undelivered quantity per day of delay shall be levied, subject to a maximum of 10 % of the value of the work order. 2. Calculation: Penalty = (Value of Undelivered Quantity) × (Penalty Rate per day) × (Number of days delayed). AMOUNT OF BID SECURITY: - RS. 250,000/-.					