



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

1	OF	6
RFQ No	IP-19885IA	
DATE	09.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017797

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

25.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Procurement of Firefighting Equipment for PSO EJHD, Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	Fire Water Hydrant EJHD EA COMPOSITION & SPECIFICATIONS (Parts of Equipment): 1. Fire Hydrant Pillar: - Wet barrel type fire Hydrant pillar (as per provided drawing) made of 6in dia. Seamless Sch. 40 pipe (Material API5L GR. B). - With inlet bottom flange 6in Weld Neck, Raised Face 150 class ANSI B16.5 (Material A-105). - 2 nos outlet nozzles 2½ dia Seamless Sch. 40 pipe BSP Male Thread for mounting of Hydrant Valve. - Flanged top with blind (for option of mounting of monitor). - Top Flange size 3in Weld neck, Raised Face 150 class meeting ANSI B16.5 & ASTM A-105. - Fitted with blind flange 150 class meeting ANSI B16.5 & ASTM A-105. 2. Hydrant Valve (2 Nos.) - Straight pattern Globe Hydrant Valve. - Bronze body with inlet 2½ in BSP Thread and British instantaneous female outlet to BS 336 size 2 ½ with cap and chain. - Manufactured to BS5154 & BS5041 Part 1. TECHNICAL DATA: a) Water Main Pressure (PSIG): - Minimum: 110 PSIG. - Maximum (Design): 165 PSIG. - Hydrostatic Test Pressure: 250 PSIG. b) Water Temperature (°F): 30-130. Item Materials: - Fire Hydrant Pillar: Material API5L GR. B. - Pipe Nipple 2-1/2": Material API5L GR. B. - Hydrant Valve: Bronze Body. - Inlet Bottom Flange: ASTM A-105 as per ASME B16.5. - Concentric Reducer: ASTM A-234 Gr. WPB as per ANSI B 16.9.			16		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

2	OF	6
RFQ No	IP-198851A	
DATE	09.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017797

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

25.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Procurement of Firefighting Equipment for PSO EJHD, Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	- Top Flange: ASTM A-105 as per ASME B16.5. - Blind Flange: ASTM A-105 as per ASME B16.5. Hydrant after Fabrication to be Corrosion Protected as follows: a. Surface preparation through standard ISO8501-1 (SA-2-1/2) immediately followed by Zinc Rich epoxy primer (Product having volume solid greater than 45) minimum thickness 120 DFT. b. Epoxy Mastic (Product having volume solid greater than 70) minimum thickness 100 DFT. c. Polyurethane Topcoat (Product having volume solid greater than 45) minimum thickness 60 DFT, in RED shade. Approvals/Certifications/Compliance: a) Each fire water hydrant assembly to be hydrostatic tested (test pressure 250 pisp, duration 5 minutes minimum) in accordance with NFPA 24 through reputed third party inspectors. The Test Certificate for each unit to be furnished at the time of supply. b) Material Test Certificate from Original Equipment Manufacturer (OEM) to be furnished by the vendor. General Requirements: - The Hydrant Assembly shall be as specified in attached drawing. Note: 1. The vendor shall be responsible for arranging an actual sample of the proposed equipment of same brand and model to demonstrate and verify all essential parameters at the PSO designated location before proceeding with the procurement. Any cost incurred for the arrangements, including but not limited to tools/equipment, bolts/nuts, flanges<(>,<)> transportation, etc., needed for the demonstration shall be borne by the vendor. Please note that the vendor can only proceed with procurement after receiving official approval from PSO. 2. Vendor must provide MTCs of pipe, flanges, blind flanges, reducer and globe valves at the time of inspection. 3. Hydrostatic Testing of all Hydrants to be witnessed by PSO					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

3	OF	6
RFQ No	IP-198851A	
DATE	09.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017797

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

25.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Procurement of Firefighting Equipment for PSO EJHD, Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
2	representative. <u>Fire Water / Foam Water Monitor</u> Construction Material: - Monitor: Stainless Steel 316L / Bronze / Brass. - Nozzle: Stainless Steel 316L / Bronze / Brass. Specifications Monitor: a) Water Flow: 750 USGPM or as per requirement. b) Control: Tiller/Knob/Hand wheel (The monitor design should be balanced for single hand easy movement by the operator.) c) Actuator: - Type: Ball Valve/Butterfly Valve. d) Stability: Locking mechanism for sweep and elevation. e) Inlet Connection: 3 inch dia. RF flange 150 lb. ANSI B16.5. f) Sweep (Rotation): 360 degrees. g) Vertical Movement: 80 degree upwards and 30 degree downwards. h) Feed Pressure: 10 bar. i) Test Pressure: 20 bar. j) Maximum Pressure: 16 bar. k) Finish: Corrosion resistant durable coating in fire brigade red shade RAL 3002. Specifications Nozzle: a) Type: Self Educting Hydro Foam Nozzle. b) Multipurpose Fixed type nozzle that can be used with foam and water. c) Foam making branch with pick up tube (3m Length). d) Throw range at 10 bar respectively minimum 80 feet (For foam making); minimum 100 feet (for straight jet). e) 3% foam proportioning via orifice disc or metering valve f) Water Flow: 750 USGPM or as per requirement. g) Nozzle Pattern: Manually adjustable straight to fog. Monitor Certification/Approval: a) FM approved or UL Listed.	EJHD	EA	8		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

4	OF	6
RFQ No	IP-198851A	
DATE	09.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017797

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

25.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Procurement of Firefighting Equipment for PSO EJHD, Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
3	Note: 1. The vendor shall be responsible for arranging an actual sample of the proposed equipment of same brand and model to demonstrate and verify all essential parameters at the PSO designated location before proceeding with the procurement. Any cost incurred for the arrangements(>,<)> including but not limited to tools/equipment, bolts/nuts, flanges, transportation, etc., needed for the demonstration shall be borne by the vendor. Please note that the vendor can only proceed with procurement after receiving official approval from PSO. <u>Hose Cabinet with Fire Hose</u> Hose Cabinet Details: - Cabinet Style: Double Door or Single Door with partition in between. - Box Dimensions: 825 (H) x 765 (W) x 375 (D) mm approx. or as per requirement, with Glass in front. - Leg Length: 400 mm. - Material: Electrogalvanized steel or Stainless Steel 304. - Thickness: 2 mm. - Installation: Floor Mounted. - Finish: Red Powder Coated (RAL number 3000). - Suitable to House: 2 no Fire Hoses and 2 no. Jet Spray Nozzles. Other Features: - Brass with chrome plate handle lock. - Solid steel cabinet door. - "FIRE HOSE CABINET" printed in white Text Size 5 inch (Front Aerial Black Bold). Hose Details: - Construction Type: Type III. - Inside/Outside coating of Synthetic Rubber. Specifications: - Dia: 2.5". - Length: 100 feet. - Working Pressure: 17 bars.	<u>EJHD</u>	<u>EA</u>	7		



5			OF			6		
RFQ No			IP-198851A					
DATE			09.08.2026					

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
 SAP No.6100017797

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED			
	ON (Date)	25.08.2026	BY (Time)	2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
 PO/DD NO. _____

Title: Procurement of Firefighting Equipment for PSO EJHD, Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	- Test Pressure: Min 325 PSI. - Bursting Pressure: Min 700 PSI. - Coupling: Aluminum/light alloy (Male & Female Coupling) Standard Compliance: - NFPA 1961 & NFPA 1963. - BS 6391. ===== WARRANTY: - Supplier will give the warranty for the equipments to be free of defects material and workmanship. Supplier will replace and install without charging any cost to PSO, any materials, supplies or equipment which fails under design conditions due to defects in material or workmanship if defect is observed and/or such failure occurs within 18 months from delivery or ONE year from date of installation/commissioning. DELIVERY PERIOD - 26 weeks from the issuance of PO. NOTES: 01. These equipment to be delivered at EJHD Karachi Aviation Station. Any kind of Transportation up to the stated location including loading, unloading of all deliverables is the sole responsibility of supplier. 02. Acceptance of equipment shall be subject to inspection by representatives of PSO representatives. 03. Quoted price should be inclusive of all taxes, duties, levies and GST. 04.Rates should include cost of all necessary accessories for proper operation of system. 05. Furnishing of Technical literature / brochure of the offered model of equipment and small accessories along with bid is must for bidders,					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

6	OF	6
RFQ No	IP-198851A	
DATE	09.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017797

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

25.08.2026

BY
(Time)

2:15 PM

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY Fix %
PO/DD NO. _____

Title: Procurement of Firefighting Equipment for PSO EJHD, Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	with duly signed and stamped by the bidder. 06. Equipment must be brand new and from fresh stock - not more than 1 year old from manufacturing date. 07. Test Certificates for Equipments (where required) to be provided by the manufacturer. 08. FXA Plate: "Fixed Asset Number (FXA)" to be printed / embossed on each equipment / machines at a clearly visible place in the following, SAMPLE format: PSO FXA # 38005765. The printing / embossing should be of permanent type and should not peel off or fade out with time. The series of Fixed Asset Numbers for all equipment / machines will be provided by PSO at the time of issuance of Purchase Order. The same number should also appear on the packing of the machine / equipment for ease of identification. 09. Supplier will provide 02 sets of Operational, Installation and Maintenance manual of the Equipment at the time of supply of equipment. 10. Vendor has to submit the filled Compliance / deviation sheet as per attached format along with bid, which must be signed and stamped by the bidder. 11. The job includes labour, transportation and all material charges. 12. The above job is subject to entire satisfaction and inspection/ acceptance by consignee. 13. Payment after completion of the job on submission of the bill, duly verified by the concerned officials. 14. If the contractor fails to complete the work within stipulated time, the concerned Incharge will be entitled to deduct from his bills for work given in this order or other minor due to him by PSO, a value of 0.1% of Work Order per day and subject to maximum 10% value of the PO. 15. PO is evaluated according to each item with lowest value of the bid. 16. Payment will be made against the vendor invoices after completion of specific job (s) and passing quality /quantity of goods/works and services including all verifications/inspections by the PSO designated official. AMOUNT OF BID SECURITY: - RS. 100,000/-.					