



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

1	OF	5
RFQ No	AM-19910AM	
DATE	19.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017897

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

03.09.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Supply, Installation, Testing <(>&<)> Commissioning of Fire Alarm System at Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	<u>FIRE ALARM CONTROL PANEL</u> Objective ===== The objective is to supply,install,test and commission a fully functional fire alarm system at Karachi Aviation (IPF), replacing the non-functional with a new, compliant and certified system meeting international and local fire safety standards. Material Details: Intelligent 1 loop fire alarm control panel with capacity of 128 addressable devices and 7 Ah battery bacup with accessories with external power supply unit for Into-Plane Facility (IPF). Note: Brand must be UL listed.	<u>Karachi</u> <u>(Aviation)</u>	<u>EA</u>	1		
2	<u>SMOKE DETECTOR</u> Intelligent optical smoke detectors with base mount isolators Technical Specifications: Type: Addressable photoelectric smoke detector with Isolator Base. IP Rating: Nema 1 rated Sensitivity: Nominal threshold of 2.4 % light grey smoke obscuration per meter Materials: PC/ABS blend (Polycarbonate / ABS) Terminals: Stainless Steel	<u>Karachi</u> <u>(Aviation)</u>	<u>EA</u>	45		
3	<u>Manual Call Point (fire alarm system)</u> Intelligent manual call points Technical Specifications: Call Point Principle: Resettable element. Single action.	<u>Karachi</u> <u>(Aviation)</u>	<u>EA</u>	6		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

2	OF	5
RFQ No	AM-19910AM	
DATE	19.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017897

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

03.09.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Supply, Installation, Testing <(>&<)> Commissioning of Fire Alarm System at Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
4	Application: Outdoor IP Rating: NEMA 3R enclosures are for outdoor use. Materials: Red Metal Construction. <u>HEAT DETECTOR</u> Intelligent ROR fixed temperature heat detectors with base mount isolators: Technical Specifications: Type: Fixed temperature heat detector Rating: IP 53 or better Sensitivity: 25 C to 90 C Materials: PC/ABS blend (Polycarbonate / ABS) Terminals: Stainless Steel.	<u>Karachi</u> <u>(Aviation)</u>	<u>EA</u>	2		
5	<u>Sounder with Flasher</u> Intelligent sounder with flasher Technical Specifications: IP Rating: NEMA 3R enclosures are for outdoor use Output: 90 DB or better Light Distribution: 15 cd - 185 cd	<u>Karachi</u> <u>(Aviation)</u>	<u>EA</u>	6		
6	<u>Alarm Bell</u> Fire Alarm bells	<u>Karachi</u> <u>(Aviation)</u>	<u>#</u>	6		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

3	OF	5
RFQ No	AM-19910AM	
DATE	19.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017897

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

03.09.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Supply, Installation, Testing <(>&<)> Commissioning of Fire Alarm System at Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
7	Technical Specifications: Application: Outdoor IP Rating: 65 or better Output: 90 dB or better Application: Outdoor. <u>1.5 sq mm 2 core fire resistant cable</u>	<u>Karachi</u> <u>(Aviation)</u>	<u>M</u>	2,000		
8	1.5 sq. mm 2 core fire retardant cable with PVC pipe and fittings. <u>Fire Alarm System at Karachi Airport</u>	<u>PSO House</u>				
8.01	<u>Installation & Commissioning</u> Services =====		<u>EA</u>	1		
	1) Design & Engineering: - Site survey and risk assessment - Fire alarm system design layout - Preparation of system architecture, loop drawings, cable routing - Compliance with NFPA, local civil defense codes, and hazardous area classifications (ATEX/IECEX) 2) Installation: - Mounting of detectors, MCPs, and alarm devices. - Cable laying and termination. - Panel installation and interconnections. - Conduit works and earthing/bonding. 3) Testing & Commissioning: - Device functionality tests (loop testing, alarm testing) - Cause and effect programming - Integration with existing system					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

4	OF	5
RFQ No	AM-19910AM	
DATE	19.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017897

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

03.09.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Supply, Installation, Testing <(>&<)> Commissioning of Fire Alarm System at Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	- Acceptance testing with client and authorities 4) Documentation & Handover - As-built drawings - System manuals and data sheets - Test reports and certification - Training material for operating personnel 5) Dismantling & Handover the old Fire Alarm System - Dismantling of old fire system. - Removal of old wiring connected with the existing system. - Removal of old panel, detectors, call points & sounders etc. - Handover the complete old accessories/items to site engineer/Location In-charge. Terms and conditions 1) Acceptance of items is subject to inspection of site engineer. 2) Items to be delivered & Installed at PSO Aviation Karachi Airport within 120 days after issuance of Purchase Order. 3) All taxes are included in the cost of PR. 4) All equipment must be certified (UL/ATEX). 5) Technicians must be trained and certified for fire alarm system installation in hazardous areas. 6) Vendor to ensure compliance with applicable fire codes (NFPA 72, 70,30). 7) Vendor shall be responsible to commission the system and have the system checked to the location engineer. 8) Any mishap cost during the project will be reimbursed by the vendor to the extent of damage. 9) Karachi Aviation Station is situated under the restricted area of Airport premises, therefore vendor is responsible to attain all the required police verifications from relevant authorities and Airport entry passes from ASF authorities. **All the work done and task completed within 120 days, after the					



5	OF	5
RFQ No	AM-19910AM	
DATE	19.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100017897

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED			
	ON (Date)	03.09.2026	BY (Time)	

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY %**
Rs. _____ **PO/DD NO.** _____

Title: Supply, Installation, Testing <(>&<)> Commissioning of Fire Alarm System at Karachi Aviation Station.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	issuance of Service Order**					