



SAP No.6100018016

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	<u>Services for Tank Chime Coating</u>	<u>Karachi</u>				
1.01	<u>chime coating</u> Scope of Work ===== The contractor shall supply all materials, labor, tools, and supervision to apply a Tank Base Seal System (TBSS) and a protective maintenance coating system on the projection plates of four designated storage tanks. The project requires sealing the chime angle to eliminate water ingress and coating the surrounding steel surfaces to prevent external atmospheric corrosion. 1) Asset Identification & Quantities The work encompasses a total linear circumference of 207.2 Meters for the chime sealing and 150 Square Meters (M²) of steel surface preparation and coating across the following four assets: ·,,Tank 7: Diameter (D) = 14.64 Meters ·,,Tank 8: Diameter (D) = 17.10 Meters ·,,Tank 9: Diameter (D) = 17.10 Meters ·,,Tank 10: Diameter (D) = 17.10 Meters 2) Working in Hazardous Zones - All operations take place in a designated hazardous terminal zone. - All mechanical cleaning, scraping, and brushing must utilize non-ferrous, non-sparking tools. 3) Priming - Apply UPS Primer continuously across both the metal annular projection plate and the adjacent concrete foundation areas for surface conditioning and promotion. - Ensure uniform coverage to promote proper adhesion and surface conditioning for the subsequent sealing layers. 4) Gap Filling	<u>(Aviation)</u>	<u>EI</u>	680		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

2	OF	4
RFQ No	AM-19914SJ	
DATE	28.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100018016

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

17.09.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Services required for Tank Chime Coating at Fuel Farm

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1.02	- Insertion of Polyethylene Foam Backer Rod between annular plate edge and concrete foundation. - Insert a Polyethylene Foam Backer Rod firmly into the gap located between the edge of the steel annular plate and the concrete foundation ring wall. - Complete the execution of the proprietary Tank Base Seal System (TBSS) over the backer rod to create a fully waterproof, flexible barrier that prevents moisture ingress beneath the tank bottoms. Removal of coating / Surface preparation Job Includes Preparation of steel structure 01 JOB 50,000 50,000 surface as per PSO approved maintenance coating system, services for surface preparation as per standard SP2-SP3 (HAND BRUSH, HAND TOOLS) Mechanical cleaning of entire surface in hazardous zone by using non-ferrous tools as per terminal engineer satisfaction.		M	150		
1.03	Application of polyamine cured epoxy mas Application of base coats of polyamine cured epoxy mastic 300 microns.		M2	150		
1.04	Application of Coating Apply a weather-resistant polyurethane final coat of (DFT-60 microns) General Points 1) Material Specifications ===== - The contractor shall provide all materials, labor, tools(>,<)> scaffolding, transportation, consumables, and supervision required for completion of the work. 2) Quality ===== - All coated surfaces shall have texture and finish. - No brush marks, roller marks, runs, sags, peeling, blistering(>,<)> or patchiness shall be acceptable. - Each coat shall be allowed adequate drying time before application of		M	150		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

3	OF	4
RFQ No	AM-19914SJ	
DATE	28.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100018016

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

17.09.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Services required for Tank Chime Coating at Fuel Farm

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	subsequent coats. - The contractor must perform magnetic gauge testing to verify the 360-micron total coating system thickness (300#m epoxy + 60#m polyurethane). - Ensure the chime seal is visually continuous, smooth, tight against both substrates, and contains no air pockets or gaps. - Final project sign-off is dependent upon a joint inspection and explicit approval by the Terminal Engineer. Terms and Conditions ===== 1) All labour, tools, and material to be provided by the contractor. 2) All HSE/Security Standards to be followed by the Contractor. 3) Contractor will provide adequate and fully functional Personal Protective Equipment to all its workers including Safety Shoes, Hard Hat, Safety Goggles, Gloves, Face masks, life lines and Safety Harnesses depending upon the nature and requirement of job and ensure their proper usage as per requirement and instructions of the Site incharge. 4) The coat quality shall be approved by the Station incharge, prior to application. 5) Contractor must assign site supervisor(s) to receive the necessary documentation including work permits and other instructions prior to start of work. The said supervisor(s) shall be available at the job site while work is being carried out. 5) Payment will be made as per actual work done. 6) Quantities against various items are estimated and may increase or decrease, however, payment shall be made as per actual verified quantities. 7) Work must be completed within 60 days of issuance of Service Order. 8) If the Contractor fails to complete the work within time					



4	OF	4
RFQ No	AM-19914SJ	
DATE	28.08.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100018016

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED			
	ON (Date)	17.09.2026	BY (Time)	

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Services required for Tank Chime Coating at Fuel Farm

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	stipulated, the Site incharge will be entitled to deduct from his bills for a value of 0.1% of work order per day and subject to maximum 10% value of P.O. 9) All Govt. taxes and SST already included in quoted rates. 10) Contractor shall provide Police verification certificates of staff/labor from local police station after issuance of Service Order.					