



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

1	OF	5
RFQ No	OP-20147NZ	
DATE	26.10.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100018802

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

06.11.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Refilling/Repair and Hydrostatic testing Of Fire Extinguishers At PSO Habibabad Depot.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	<u>Re-filling of Fire Cylinders & Trolleys</u>	<u>Habibabad (Depot)</u>				
1.01	<u>Filling of DCP Fire Extinguishers</u> Re-Filling of DCP Fire extinguishers upto design pressure as per the following quantities: TYPE,,,, DCP 12KG,,,,-11NOS DCP 6KG,,,,,-02NOS DCP 50KG,,,,-11Nos Note: 1. Vendor to fill the DC Powder on site by weight in the presence of PSO staff. 2. All the cylinders will be pressurized as per the cylinder design pressure. Nitrogen cylinders of the vendor must be equipped with Pressure regulator along with calibrated inlet and outlet pressure gauges. 3. All Cylinders shall be properly sealed with tamper-evident seals.		<u>KG</u>	700.000		
1.02	<u>Filling of CO2 fire extinguisher</u> Re-Filling Of CO2 Fire extinguishers upto design pressure as per the following quantities: TYPE,,,,,-QTY CO2 05KG,,,,-15NOS COS 03KG,,,,-04NOS CO2 30KG TROLLEY-01NOS		<u>KG</u>	117.000		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

2	OF	5
RFQ No	OP-20147NZ	
DATE	26.10.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100018802

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

06.11.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Refilling/Repair and Hydrostatic testing Of Fire Extinguishers At PSO Habibabad Depot.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	Note: - Filling shall be conducted in the presence of the PSO Engineer, either at site or at the contractor's testing facility. In case of off-site testing, transportation of the Engineer to and from the testing facility shall be the contractor's responsibility. - PSO engineer shall also verify the weight of all cylinders before and after the filling preferably at a weight bridge and contractor shall be responsible for the arrangement of the same. - All Cylinders shall be properly sealed with tamper-evident seals.					
1.03	<u>Providing & Replac. of Hose Pipe for FEs</u> Supply and replacement of damaged discharge Hose Pipe and Horns of CO2 Fire Extinguishers.		<u>EA</u>	10		
1.04	<u>Providing & Replac. of Hose Pipe for FEs</u> Supply and replacement of damaged operating valve of CO2/DCP cylinders.		<u>EA</u>	15		
1.05	<u>Providing & Replac. of Hose Pipe for FEs</u> Supply and Replacement of of faulty pressure gauges of fire Cylinders/Trolleys		<u>EA</u>	15		
1.06	<u>Providing & Replac. of Hose Pipe for FEs</u> Provision and replcement of discharge hose pipe and horn of DCP fire extinguishers.		<u>EA</u>	10		
1.07	<u>Providing & Replac. of Hose Pipe for FEs</u> Supply and repalcement pairs of damaged Tyres for CO2 and DCP TROLLEYS Fire Extinguishers.		<u>EA</u>	5		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

3	OF	5
RFQ No	OP-20147NZ	
DATE	26.10.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100018802

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

06.11.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Refilling/Repair and Hydrostatic testing Of Fire Extinguishers At PSO Habibabad Depot.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1.08	<u>Providing & Replac. of Hose Pipe for FEs</u> Provision and replacement of discharge hose pipe and horn of DCP 50KG trolleys.		<u>EA</u>	8		
1.09	<u>Providing and applying enamel</u> All cylinders/trolleys (Total 44Nos)to be repainted with 02 coats of Post Office Red Enamel color after proper cleaning and surface preparation with primer where required as per satisfaction of M<(>&<)>R Engineer.		<u>M2</u>	70		
1.10	<u>Providing & Replac. of Hose Pipe for FEs</u> Supply and replacing of Hose pipe for 30kg CO2 Trolley.		<u>EA</u>	1		
1.11	<u>Providing & Replac. of Hose Pipe for FEs</u> Supply and replacement of damaged operating valve of 50kg DCP Fire Trolleys.		<u>EA</u>	5		
1.12	<u>Hydrostatically Pressure testing</u> Hydrostatic testing of CO# and DCP fire extinguishers, including portable and trolley-mounted units, shall be carried out as per applicable NFPA 10 requirements and relevant cylinder specifications, including inspection, testing at specified pressure and holding time, and provision of test certificates. Testing shall be conducted in the presence of the PSO Engineer, either at site or at the contractor's testing facility. In case of off-site testing, transportation of the Engineer to and from the testing facility shall be the contractor's responsibility. All testing equipment and related arrangements shall be provided by the contractor.		<u>EA</u>	44		
1.13	<u>INSTALLATION OF FIRE EXTINGUISHER</u> Providing hanging arrangement for DCP and CO2 Fire extinguishers 3 to 12 kg on wall. Suitable hooks to be provided as per the sizes and weights of cylinders.		<u>EA</u>	60		
1.14	<u>INSTALLATION OF FIRE EXTINGUISHER</u> Supply and installation of inspection card for all fire extinguishers.		<u>EA</u>	60		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

4	OF	5
RFQ No	OP-20147NZ	
DATE	26.10.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100018802

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

06.11.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Refilling/Repair and Hydrostatic testing Of Fire Extinguishers At PSO Habibabad Depot.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1.15	Card must have at least 12 rows for monthly inspection. Card should be weather proof with suitable writing arrangement for outdoor use. <u>INSTALLATION OF FIRE EXTINGUISHER</u> Operating Instructions sticker must be pasted on all Fire Extinguisher as per the type and capacity. Stickers must be Weather resistant with minimum. Size 12" x 10" (for trolleys) and 5" x 8" (for rest) with Self Adhesive, Weatherproof and UV Protected and must remain intact and readable for at least one year. ===== TERMS AND CONDITIONS: ===== 1.All the cylinders/trolleys will not be provided at the same time in one go for refilling/repairing. To ensure safety at Location, equipment will be provided in parts (at max 1/2 of total quantity). Whether the Vendor brings the filling setup at Depot or refills the cylinders at his workshop, that will be as per the discretion of location engineer or Depot incharge. In case of off-site filling(>,<)> contractor shall arrange transportation of PSO engineer and filling/testing activities shall be performed in presence of PSO engineer. 2. All applicable Govt Taxes are included in the given rates. 3.All cylinders/trolleys to be repainted with Red Enamel color after proper cleaning and surface preparation with primer where required. 4. Job will be executed as per satisfaction and instructions of the location engineer. Depot Engineer has right to reject any substandard product being used/provided. 5.Vendor will give demonstration/Training on use of fire		EA	44		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

5	OF	5
RFQ No	OP-20147NZ	
DATE	26.10.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100018802

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

06.11.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Refilling/Repair and Hydrostatic testing Of Fire Extinguishers At PSO Habibabad Depot.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	extinguishers/trolleys to the staff. 6. Contractor shall be responsible for any leakage or malfunction of cylinders for the period of atleast one year and shall replace/refill or repair without any additional cost. 7. Transportation charges/Labor charges are included in the given rates. 8. The contractor has to maintain the overall House Keeping of the Site. 9. Payment will be made as per actual quantity of Work Done. 10. Tools, equipment, PPEs and manpower required for the job will be provided by the contractor. 11. If the Contractor fails to complete the work within the time stipulated i.e 15 days after issuance of SO and, the Engineer Incharge will be entitled to deduct from his bills for work given in this order <(>,<)> a value of 0.1% of Work Order per day and subject to maximum 10% Value of P.O.					